

# Fire Alarm/Fire Sprinkler Notice

All Commercial Contractors

The Creve Coeur Fire Protection District requires **separate permits for fire alarm systems and/or fire sprinkler systems**. Your architectural drawing may show placement of fire alarm devices or sprinkler head locations; however, you are still required to submit two sets of signed and sealed drawings for separate Fire District Fire Alarm or Fire Sprinkler Permits.

If you have a small project, the addition or relocation of **THREE OR MORE** fire alarm devices such as smoke detectors, horn/strobes, etc., or fire sprinkler heads will require a permit from the Fire District. **Less than 3 devices or relocations require no permit.**

If you are not sure if a separate fire alarm permit is required on your project, please contact the Fire Marshal's Office at 314-432-5570. It is the General Contractor's responsibility to make sure that **both** fire alarm and fire sprinkler permits have been secured, and that approved drawings are on the job site for final inspection and subsequent approval.

1/1/2015